HermanMiller

Aeron



For more information about our products and services or to see a list of dealers, please visit us at www.hermanmiller.com or call 888 - 443 - 4357.

© 2016 Herman Miller, Inc., Zeeland, Michigan Printed in U.S.A. Part No. 1BHGYK - A.

Tools Required





Hammer

Safety Glasses



Wrench 10 mm



Electric Drill



New Aeron Task Chair & Work Stool Disassembly for Recycling

Materials Identification and Segregation:

Where possible, plastic components are marked with ASTM recycling codes. Use these codes to identify material type for recycling. Non marked components should be treated as mixed plastic. Ferrous metals can be identified using a small magnet for recycling. Non-ferrous metals should be separated and recycled separately.









Special punch with recess

T40, T25 Torx bit

5mm, 6mm Hex bit

Step 1

Nylon cap

1.1 Remove the four back bolts using 5mm Hex bit.



1.2



1.3 Detach the Back from the chair

Step 2

2

2.1 Remove the bolt from the right swing arm.





2.2 Right hand arm has right hand drive threads.

2.3 Follow the previous steps to remove the left arm. Left hand arm has reverse left hand drive threads.





3.1 Remove nut and shoulder bolt

3.2 Use T27 Torx driver and 10 mm wrench





3.4 Follow previous steps to remove the right side nut and shoulder bolt







3.7 Follow the previous step to remove the bolt on the other side.







3.9 Detach the seat from the swing arm

4.1 Remove the lower cover by releasing the 4 snaps





4.2 Squeeze the snaps as indicated below to remove the cover

4.3 Detach the lower cover from the tilt assembly.







G

4.6 Remove the front cover.

4.7





5.1 Detaching director from the tilt housing.

5.2 Release the two snaps shown below.





5.4 Lift the director from the tilt housing.









5.7 Slide out the cable to detach from the actuator.

5.8 Removing the handle from the swing arm.









5.11

5.12 Release the bracket out of the socket.









6.1 Detach the swing arms.

6.2 Pull out the swing arms from the assembly.





6.3 Rotate the knob counter clock wise to release tension

6.4 Remove the cassette screws.





6.5 Use T25 Drive to remove the screws.

6.6 Detach the retainer clips from the assembly.





6.7 Detach the tension knob and the tilt lever.

6.8 Use the swing arm and pull back and hold to release the forward limit.





6.9 While holding back swing arm, lift the tab to disengage the forward limit.





6.11 Rotate the casing to remove the leaf spring from the assembly.





6.13 Detach the Leaf spring from the assembly.







6.17 Remove the other pivot pin joint using the previous step.



6.18





6.20 Detach the tilt casting from assembly.





6.21 Use hammer and punch to tap out the bushing to remove the B-Link





6.23 Follow the previous step to remove the right hand side bushing.

6.24





6.25 Detach the B-Link from the assembly.

6.26 Use T25 Torx bit to remove the cassette bolts









6.29

6.30





6.31 After removing all the cassette bolts detach the tilt cassette.

6.32 Use a punch with recess and hammer to remove the tilt housing.

Attention: Hold the tilt casting and lift the whole unit in the air before hammering.





Step 7

7.1 Removing foot ring for work stool. Unlock the foot ring by holding base and turn counter clockwise. To remove the cylinder for the Aeron Task chair skip to step 7.6.









7.4 Place a nylon cap at the bottom of the cylinder. Use dead blow hammer and hit the bottom of the base.

7.5 Detach the base from the cylinder. To remove the castors skip to step 7.8 $\,$





7.6 Removing the cylinder for the Aeron chair. Use nylon cap and Hammer to remove the cylinder form the base.





7.8 Pull off the castors to disassemble from the base







8.1 Slide the lumbar assembly upwards to detach from the back.





8.3 The strap and the pad can be detached from the bow by using pistol grip style bar clamp.





8.5 Remove the two T-20 flat head screws that secure the Flexi-rack to the back.

8.6 Screws removed.





8.7 Use a hammer to tap up on underside of the wishbone to disengage it from the back.

8.8 Remove the unit from the back.





8.9 Remove the posture fit pad assembly by sliding up to release from the t-slot and rotating away from wishbone to disengage pivot from the flexi rack.

8.10 Remove the two T-27 pan head screw that secure the cover of the wish bone.





8.11 Remove the cover from the wishbone.







8.13 Remove the bevel gear from the wishbone.

8.14 Remove the flexi-rack from the wishbone.





Step 9

9.1 Remove the screws to detach the frame from the back assembly.











10.1 Remove the screws to detach the frame from the seat assembly.









11.1 Remove the screws from the bottom cap.









11.5

11.6 Slide the tube and the top cap out.









11.9 Remove the screws from the bottom cap.







11.11 Remove the screws from the foot ring tread to separate the tread.

11.12



11.13 Unsnap three icon plugs from the foot ring.



